



BATTERY-BOX PREMIUM LVS LITE MINIMUM CONFIGURATION LIST V1.0

Compatible Inverter (1 phase)		ON Grid		ON Grid + Backup	
		Module	Tower (PDU)	Module	Tower (PDU)
Selectronic	SPMC480-AU	≥1	≥1	≥2	≥1
	SPMC481-AU	≥1	≥1	≥3	≥1
	SPMC482-AU	≥2	≥1	≥5	≥2
	Battery firmware: BMU ≥ V1.17, BMS ≥ V1.8; Selectronic SP Link firmware ≥ 14.20.x, SP Pro firmware ≥ V12.x				

Note:

- ✦ The Information in this document is subject to change without notice. Every effort has been made to make this document complete, accurate, and up-to-date. However, BYD may need to make some improvements under certain circumstances without advance notice. Please take the latest version of this document at our websites into account.
- ✦ No more than 4 module could be installed in one tower.
- ✦ No parallel connection is allowed.

